

CERTIFICAT

CERTIFICADO

'EP'ITITAT

認証証書

CERTIFICATE

ZERTIFIKAT

CERTIFICATE / SERTİFİKA

Fire test on PN 110 (600 #) and DN 400 (16") BALL Valve
PN 110 (600 #) ve DN 400 (16") Küresel Vana Yangın Testi

User " Kullanıcı" : General / Genel
Project No. " Proje No" : TGK 04-3711R (001)
Manufacturer İmalatçı : VASTAŞ Valf Armatürleri San. Ve Tic A.Ş.
Çerkezköy - Tekirdağ - TURKEY
Manufact. project no. İmalatçı Proje no : Fire Test for PN 110 (600 #) and DN 400 (16") BALL Valve
PN 110 (600 #) ve DN 400 (16") Küresel vana yangın testi
Manufacturer year İmalat Yılı : 2004
Drawings No. Resim No. : In the related Vastaş drawing No: P14.400.01
Vastaşın ilgili Resim No : P14.400.01
Max working pres. Max. Çalışma Basıncı : 102 Bar (PN 110 (600 #))
Related test standart Test Standardı : API 6FA and ISO 10497

Valve which has properties PN 110 (600 #) and DN 400 (16") BALL Valve has been Fire tested According to related standarts API 6FA and ISO 10497 under observation of TUV SUD. Inspector in the VASTAŞ Factory for general using purpose. After the satisfactory results related Fire Test report of valve has been approved by TUV Inspector. TUV SUD. Inspector prepared and approved this certificate Due to Client request.

PN 110 (600 #) ve DN 400 (16") özelliklerine Sahip Vananın ilgili standartlar API 6FA ve ISO 10497 taleplerine göre Yangın Testlerine TUV SUD elemanı nezaret ederek Test sonucu olumlu bulunan ilgili vanaya ait firma tarafından düzenlenen Yangın testi Raporu onaylanmış ve firma talebi doğrultusunda bu Sertifika düzenlenerek firmaya sunulmuştur.

Test Date "Test Tarihi" : 25.05.2004
Test Place "Test Yeri" : Çerkezköy / Tekirdag TURKEY
Qualification Range Kalifikasyon oranı : DN 400 (16") and Above; PN 110 (600 #) and
PN 150 (900 #)
Anex "Ekler" : One page Test Report "1 sayfa Test raporu"
Test Result Test Sonucu : Satisfactory
Uygun bulunmuştur.

Place / yer	Date / tarih	TÜV SÜDDEUTSCHLAND TGK
Istanbul-TURKEY	03.06.2004	HAKIM OZLUK