

CERTIFICATE / SERTİFİKA

**Fire test on PN 50 (300 #) and DN 50 (2") GATE Valve
PN 50 (300 #) ve DN 50 (2") GEYT Vana Yangın Testi**

User " Kullanıcı " : General / Genel
Project No. " Proje No " : TGK 04-3711R (015)
Manufacturer İmalatçı : VASTAŞ Valf Armatürleri Sanayi Tic A.Ş.
Çerkezköy - Tekirdağ - TURKEY
Manufact. project no. İmalatçı Proje no : Fire Test for PN 50 (300 #) and DN 50 (2") GATE Valve
PN 50 (300 #) ve DN 50 (2") GEYT vana yangın testi
Manufacturer year İmalat Yılı : 2007
Drawings No. Resim No. : In the related Vastaş drawing No: VA CO. 02
Vastaşın ilgili Resim No : VA CO. 02
Max working pres. Max. Çalışma Basıncı : 50 Bar (PN 50 (300 #))
Related test standart Test Standardı : API 6FA and ISO 10497/ 2004

Valve which has properties PN 50 (300 #) and DN 50 (2") GATE Valve has been Fire tested According to related standards API 6FA and ISO 10497/2004 under observation of TUV SUD. Inspector in the VASTAŞ Factory for general using purpose. After the satisfactory results related Fire Test report of valve has been approved by TUV Inspector. TUV SUD. Inspector prepared and approved this certificate Due to Client request.

PN 50 (300 #) ve DN 50 (2") özelliklerine Sahip GEYT Vananın ilgili standartlar API 6FA ve ISO 10497/2004 taleplerine göre Yangın Testlerine TUV SUD elemanı nezaret ederek Test sonucu olumlu bulunan ilgili vanaya ait firma tarafından düzenlenen Yangın testi Raporu onaylanmış ve firma talebi doğrultusunda bu sertifika firmaya sunulmuştur.

Test Date "Test Tarihi" : 07.08.2007
Test Place "Test Yeri" : Çerkezköy / Tekirdag TURKEY
Qualification Range Kalifikasyon oranı : Below DN 50 & DN 50 (2"), DN 65 (2 1/2"), DN 80 (3"),
DN 100 (4"); PN 40, PN 63, PN 50 (Class 300),
PN 100 (Class 600)
Anex "Ekler" : One page Test Report "1 sayfa Test raporu"
Test Result Test Sonucu : Satisfactory
Uygun bulunmuştur.

Place / yer : Istanbul-TURKEY
Date / tarih : 07.08.2007

