

## CERTIFICATE / SERTİFİKA

**Fire test on PN 20 (150 #) and DN 50 ( 2") GATE Valve  
PN 20 (150 #) ve DN 50 ( 2") GEYT Vana Yangın Testi**

<b>User " Kullanıcı"</b>	:	General / Genel
<b>Project No. " Proje No"</b>	:	TGK 04-3711R ( 014 )
<b>Manufacturer İmalatçı</b>	:	VASTAŞ Valf Armatürleri Sanayi Tic A.Ş. Çerkezköy - Tekirdağ - TURKEY
<b>Manufact. project no. İmalatçı Proje no</b>	:	Fire Test for PN 20 (150 #) and DN 50 (2") GATE Valve PN 20 (150 #) ve DN 50 ( 2" ) GEYT vana yangın testi
<b>Manufacturer year İmalat Yılı</b>	:	2007
<b>Drawings No. Resim No.</b>	:	In the related Vastaş drawing No: VA CO. 02 Vastaşın ilgili Resim No : VA CO. 02
<b>Max working pres. Max. Çalışma Basıncı</b>	:	20 Bar (PN 20 (150 #) )
<b>Related test standart Test Standardı</b>	:	API 6FA and ISO 10497/ 2004

Valve which has properties PN 20 (150 #) and DN 50 ( 2" ) GATE Valve has been Fire tested According to related standart API 6FA and ISO 10497/2004 under observation of TUV SUD. Inspector in the VASTAŞ Factory for general using purpose. After the satisfactory results related Fire Test report of valve has been approved by TUV Inspector. TUV SUD. Inspector prepared and approved this certificate Due to Client request.

PN 20 (150 #) ve DN 50 ( 2" ) özelliklerine Sahip GEYT Vananın ilgili standartlar API 6FA ve ISO 10497/2004 taleplerine göre Yangın Testlerine TUV SUD elemanı nezaret ederek Test sonucu olumlu bulunan ilgili vanaya ait firma tarafından düzenlenen Yangın testi Raporu onaylanmış ve firma talebi doğrultusunda bu sertifika firmaya sunulmuştur.

<b>Test Date "Test Tarihi"</b>	:	07.08.2007
<b>Test Place "Test Yeri"</b>	:	Çerkezköy / Tekirdag TURKEY
<b>Qualification Range Kalifikasyon oranı</b>	:	Below DN 50 & DN 50 (2"), DN 65 (2 1/2"), DN 80 (3"), DN 100 (4"); PN 20 (Class 150), PN 25, PN 40, PN 50 (Class 300)
<b>Anex "Ekler"</b>	:	One page Test Report "1 sayfa Test raporu"
<b>Test Result Test Sonucu</b>	:	Satisfactory Uygun bulunmuştur.

Place / yer	Date / tarih
Istanbul-TURKEY	07.08.2007

TÜV Industrie Service GmbH  
TÜV SÜD Gruppe  
TÜV SÜD / Türkiye  
Yıldız Posta Cad. No.17 Kat:5  
TR-34394 Esentepe / İstanbul / TÜRKİYE

Tel. : (+90) 212 347 98 10  
Fax : (+90) 212 347 98 11  
e-mail: info@tuv-sud.com.tr



Mitglied der  
CONFÉDERATION EUROPÉENNE

**CEOC**

D'ORGANISMES DE CONTROLE