

CERTIFICAT

CERTIFICADO

'EPTİTİTAT

認証証書

CERTIFICATE

ZERTIFIKAT

CERTIFICATE / SERTİFİKA

Fire test on PN 20 (150 #) and DN 100 (4") PLUG Valve
PN 20 (150 #) ve DN 100 (4") PLUG Vana Yangın Testi

User " Kullanıcı" : General / Genel
Project No. " Proje No" : TGK 04-3711R (009)
Manufacturer : VASTAŞ Valf Armatürleri San. Ve Tic A.Ş.
İmalatçı : Çerkezköy - Tekirdağ - TURKEY
Manufact. project no. : Fire Test for PN 20 (150 #) and DN 100 (4") PLUG Valve
İmalatçı Proje no : PN 20 (150 #) ve DN 100 (4") PLUG vana yangın testi
Manufacturer year : 2005
İmalat Yılı
Drawings No. : In the related Vastaş drawing No: P 105
Resim No. : Vastaşın ilgili Resim No : P 105
Max working pres. : 20 Bar (PN 20 (150 #))
Max. Çalışma Basıncı :
Related test standart : API 6FA and ISO 10497
Test Standardı :

Valve which has properties PN 20 (150 #) and DN 100 (4") PLUG Valve has been Fire tested According to related standarts API 6FA and ISO 10497 under observation of TUV SUD. Inspector in the VASTAŞ Factory for general using purpose. After the satisfactory results related Fire Test report of valve has been approved by TUV Inspector. TUV SUD. Inspector prepared and approved this certificate Due to Client request.

PN 20 (150 #) ve DN 100 (4") özelliklerine Sahip PLUG Vananın ilgili standartlar API 6FA ve ISO 10497 taleplerine göre Yangın Testlerine TUV SUD elemanı nezaret ederek Test sonucu olumlu bulunan ilgili vanaya ait firma tarafından düzenlenen Yangın testi Raporu onaylanmış ve firma talebi doğrultusunda bu Sertifika düzenlenerek firmaya sunulmuştur.

Test Date "Test Tarihi" : 23.11.2005
Test Place "Test Yeri" : Çerkezköy / Tekirdag TURKEY
Qualification Range : DN 100 (4"), DN 125 (5"), DN 150 (6"), DN 200 (8")
Kalifikasyon oranı : PN 20, PN 25, PN 40, PN 50
Anex "Ekler" : One page Test Report "1 sayfa Test raporu"
Report no: QA-FT-05-02
Test Result : Satisfactory
Test Sonucu : Uygun bulunmuştur.

Place / yer	Date / tarih	TÜV Súddeutchland TGK
Istanbul-TURKEY	23.11.2005	HAKIM OZLUK